GENERAL NOTES

A. 12.47KV CABLE LENGTH IS AN ESTIMATE.

B. VCL – VARNISHED CAMBRIC LEAD SHEATH

SHEET NOTES (4)

1. 208Y/120V
2. 480Y/277V
3. 12KV/4160 DELTA
4. PARTIAL DISCHARGE SENSORS (3)
5. PARTIAL DISCHARGE SENSOR (1)

BUILDING IDENTIFICATION

WHP – WEST HEATING PLANT
PSC – PETER SCOTT CENTER
ML – MILLAR LIBRARY
SC1 – SCIENCE BUILDING 1
SC2 – SCIENCE BUILDING 2
LH – LINCOLN HALL
XSB – EXTENDED STUDIES BUILDING
CH – CRAMER HALL
CHSE – CRAMER HALL SOUTHEAST
CHNW – CRAMER HALL NORTHWEST
US – UNIVERSITY SERVICE AND PARTIAL H2
SM – SMITH MEMORIAL
SU – STUDENT UNION
LE – LIBRARY EAST
NH – NEUBERGER HALL
NHS – NEUBERGER HALL SOUTH
PF1 – PARKING FACILITY #1

GLUMAC engineers for a sustainable future
339 SW Washington St., Suite 200
Portland, OR 97204
T: 503.227.5280 F: 503.274.7674
Job No.: 02.120607
Contact: J. EDMISTER
www.glumac.com

Title: WEST CAMPUS INFRASTRUCTURE - ELECTRICAL ONE-LINE DIAGRAM

Project: PORTLAND STATE UNIVERSITY

724 S.W. HARRISON ST. PORTLAND, OREGON

Revisions:
DRAFT 1/16/2013

Drawing No.: HV-100

Scale:

Date: