



**Oregon State
University**

**Construction Contracts
Administration, Procurement
Contracts & Materials
Management (PCMM)**
Oregon State University
644 SW 13th Ave.
Corvallis, Oregon 97333

**P 541-737-4261
F 541-737-5546
oregonstate.edu**

11/13/2018

Oregon State University
Construction Contract Administration
Pharmacy Chiller Replacement Rebid

ADDENDUM NO. 2

THIS ADDENDUM IS BEING ISSUED for clarification and/or revisions of the drawings and specifications as noted. This document is hereby made a part of the Contract Documents to the extent as though it was originally included herein.

QUESTIONS and ANSWERS:

- Item 1 Q: Is there an approved air coil manufacturers list for this project?
 A: Coil manufacturers that meet the specifications and performance requirements are acceptable.
- Item 2 Q: The air coil specification indicates “cleanable tube” and makes reference to unions or flanges. Does this pertain to the DX coils for this project?
 A: Union/flange connections and sloped cleanable tube connections apply to chilled water coils (not included in this project). Install DX coils per manufacturer recommendations.
- Item 3 Q: Are there any “E” sheets for this project showing the electrical scope in greater detail?
 A: No “E” sheets are provided for this project. See Addendum #1 for additional clarification on the electrical scope.

END OF ADDENDUM NO. 2