

Construction Contracts
Administration, Procurement
Contracts & Materials
Management (PCMM)
Oregon State University
644 SW 13th Ave.
Corvallis, Oregon 97333

P 541-737-3401 **F** 541-737-5546 oregonstate.edu

5/28/2019

Oregon State University
Construction Contract Administration
ITB 199053 – MERRYFIELD HALL RENOVATION RE-BID

ADDENDUM NO. 7

<u>THIS ADDENDUM IS BEING ISSUED</u> for clarification and/or revisions of the Solicitation Documents as noted. This document is hereby made a part of the Solicitation Documents to the extent as though it was originally included therein.

The BID DUE DATE/TIME has been changed to Tuesday, June 4, 2019 at 2:00 PM Pacific Time. Included with this addendum is a REVISED BID FORM – ADDENDUM 7, which shall replace any/all previous Bid Forms and shall be submitted with the Bid.

END OF ADDENDUM NO. 7

OREGON STATE UNIVERSITY

REVISED BID FORM – ADDENDUM 7

PROJECT:		MERRYFIELD HALL RENOVATION – RE-BID					
BID DUE DATE/TIME:		JUNE 4, 2019 AT	2:00 PM PACIFIC TIME				
FROM							
	Name of Contractor						
TO: Oregon State University ("Owner") Construction Contract Administration 644 SW 13 th Street Corvallis, Oregon 97333							
1.	The Undersigned (check one of the following and insert information requested):						
	a. An individual doing business under an assumed name registered under the laws of the State of; or						
	b. A partnership registered under the laws of the State of; or; or; or; or; or; or; d. A limited liability corporation/company organized under the laws of the State of;						
	hereby proposes to furnish all material and labor and perform all work hereinafter indicated for the above project in strict accordance with the Contract Documents for the Basic Bid as follows:						
			Dollars (\$)			
	and the Undersigned agrees to be bound by the following documents:						
	 Notice of Opportur Supplemental Instruction Performance Bond at Supplemental OSU Control Prevailing Wage Rater Plans and Specification 	etions to Bidders nd Payment Bond General Conditions tes	 Instructions to Bidders Sample Contract OSU General Conditions Payroll and Certified Statement Form Drawings and Details 				
	• ADDENDA number	ed through	, inclusive (fill in blanks)				

2. The Undersigned proposes to add to or deduct from the Base Bid indicated above the items of work relating to the following Alternate(s) as designated in the Specifications:

MERRYFIELD HALL RENOVATION – RE-BID REVISED BID FORM – ADDENDUM 7 PAGE 2

ADD/DEDUCT: \$_____

ALTERNATE M1: Deletion: Sheets M3A, M4A, M5A, M6A, M7A, M8A: Deleted new VRF fan coil systems serving Labs A, B, C, D, and E. This includes deleting the heat pumps, refrigerant piping, ductwork, diffusers, return grilles, and DDC controls associated with the fan coils. This also includes
ADD/DEDUCT: \$
ALTERNATE M2: Addition: Sheets M1A, M3A: Added the removal and replacement of the existing steam and condensate piping in the crawl space under the area of work. This includes confirming the size of the existing steam and condensate piping in the crawl space.
ADD/DEDUCT: \$
ALTERNATE M3: Addition: Sheets M3A, M4A, M5A, M6A, M7A, M8A, M11A: Added new steam reheat coils for the supply air valves serving Labs A, B, C, D, and E. This includes adding new steam piping to serve the new steam reheat coils. This also includes adding associated DDC controls.
ADD/DEDUCT: \$
ALTERNATE M4: Change: Sheets M4A, M6A: Increased the capacity of AHU-1 since it will now be cooling and partially heating Labs A, B, C, D, and E instead of just providing neutral outside air to the spaces.
ADD/DEDUCT: \$
ALTERNATE M5: Addition: Sheet M3A, M5A, M7A: Increased size of heat pump (adding second unit) serving AHU-1 due to the increased capacity of AHU-1.
ADD/DEDUCT: \$
ALTERNATE M6: Addition: Sheet M4A, M9A: Added energy code required economizer bypass ductwork, dampers, and controls for AHU-1.
ADD/DEDUCT: \$
ALTERNATE E1: Deletion: Sheets E4A, E5A, E11A: Deleted the electrical power for the fan coils and VRF heat pumps serving Labs A, B, C, D, and E. This includes deleting associated circuit breakers,
wiring, and disconnects. ADD/DEDUCT: \$
ALTERNATE E2: Change: Sheets E11A: Increased the wire size for AHU-1 due to the increased
capacity of AHU-1. ADD/DEDUCT: \$
ALTERNATE E3: Addition: Sheet E4A, E11A: Added electrical power for HP-AHU-1 due to the increased capacity of AHU-1. This includes adding associated circuit breaker, wiring, and disconnect.

- 3. The work shall be completed within the time stipulated and specified in Division 1, Section 01 11 00, of the Specifications.
- 4. The Undersigned certifies that: (1) This Bid has been arrived at independently and is being submitted without collusion with and without any agreement, understanding, or planned common course of action with any other vendor of materials, supplies, equipment or services described in the invitation to bid designed to limit independent bidding or competition; and (2) The contents of the Bid have not been communicated by the Undersigned or its employees or agents to any person not an employee or agent of the Undersigned or its surety on any Bond furnished with the Bid and will not be communicated to such person prior to the official opening of the Bid.
- 5. The undersigned **HAS**, **HAS NOT** (*circle applicable status*) paid unemployment or income taxes in Oregon within the past 12 months and **HAS**, **HAS NOT** (*circle applicable status*) a business address in Oregon.
- 6. The Undersigned agrees, if awarded a contract, to comply with the provisions of ORS 279C.800 through 279C.870 pertaining to the payment of the prevailing rates of wage.
- 7. Contractor's CCB registration number is ______. As a condition to submitting a bid, a Contractor must be registered with the Oregon Construction Contractors Board in accordance with ORS 701.035 to 701.055, and disclose the registration number. Failure to register and disclose the number will render the bid unresponsive and it will be rejected, unless contrary to federal law.
- 8. The successful Bidder hereby certifies that all subcontractors who will perform construction work as described in ORS 701.005(2) were registered with the Construction Contractors Board in accordance with ORS 701.035 to 701.055 at the time the subcontractor(s) made a bid to work under the Contract.

9.	successful Bidder hereby certifies that, in compliance with the Worker's Compensation Law of				
the Stat	of Oregon, its Worker's Compensation Insurance provider is				
Policy 1	o, and that Contractor shall submit Certificates of Insurance as required.				
-	•				
10.	Contractor's Project Manager for this project is:,				
Office 1	none: Cell Phone: .				

- 11. The Undersigned certifies that it has not discriminated against minority, women, or emerging small businesses in obtaining any subcontracts for this project.

MERRYFIELD HALL RENOVATION – RE-BID REVISED BID FORM – ADDENDUM 7 PAGE 4

By signature below, C	Contractor agrees to be bound by th	is Bid.
	NAME OF FIRM	
	ADDRESS	
	FEDERAL TAX ID	
	TELEPHONE NO	
	FAX NO	
	SIGNATURE 1)	
		Sole Individual - Signature
		Sole Individual - Printed Name
	or 2)	Partner
		Parmer
	or 3)	Authorized Officer of Corporation - Signature
(SEAL)		Authorized Officer of Corporation Printed Name
		Attested: Secretary of Corporation

Payment information will be reported to the IRS under the name and taxpayer ID # provided above. Information not matching IRS records could subject Contractor to 31 percent backup withholding.

**** END OF BID ****