



Oregon State University

FOUNDATION BUILDING RENEWAL

PROJECT NUMBER: 2163-19

ITB #199445

ADDENDUM NO. 2

ISSUE DATE: June 11, 2019

CONTRACT ADMINISTRATOR:

Brooke Davison, Construction Contracts Officer

Construction Contracts Administration

Email: ConstructionContracts@oregonstate.edu

This Addendum is hereby issued to inform you of the following revisions and or clarifications to the above-referenced ITB and/or the Contract Documents for the Project, to the extent they have been modified herein. Any conflict or inconsistency between this Addendum and the Solicitation Document or any previous addenda will be resolved in favor of this Addendum. Bids shall conform to this Addendum. Unless specifically changed by this Addendum, all other requirements, terms and conditions of the Solicitation Document and or Contract Documents, and any previous addenda, remain unchanged and can be modified only in writing by OSU. The following changes are hereby made:

TECHNICAL SPECIFICATIONS:

- | | |
|--------|---|
| Item 1 | Section 08 71 00 FINISH HARDWARE – DELETE Hardware Schedule located at the end of the specification. Hardware Schedule located in Sheet A8 of the drawings shall prevail. |
| Item 2 | Section 08 80 00 INSULATING GLASS – paragraph 2.01, DELETE reference to insulated glazing. All glass provided for in this project shall be single pane glazing (1/4" thick). Provide tempered glass where specified and required by code. |

END OF ADDENDUM NO. 2