



Oregon State University

SPORTS PERFORMANCE CENTER WEIGHT ROOM REFRESH

PROJECT NUMBER: 2147-19

INVITATION TO BID #2019-000041

ADDENDUM NO. 2

ISSUE DATE: July 9, 2019

CONTRACT ADMINISTRATOR:

Shoshana Shabazz, Purchasing Analyst

Construction Contracts Administration

Email: ConstructionContracts@oregonstate.edu

This Addendum is hereby issued to inform you of the following revisions and or clarifications to the above-referenced ITB and/or the Contract Documents for the Project, to the extent they have been modified herein. Any conflict or inconsistency between this Addendum and the Solicitation Document or any previous addenda will be resolved in favor of this Addendum. Bids shall conform to this Addendum. Unless specifically changed by this Addendum, all other requirements, terms and conditions of the Solicitation Document and or Contract Documents, and any previous addenda, remain unchanged and can be modified only in writing by OSU. The following changes are hereby made:

TECHNICAL SPECIFICATIONS:

- Item 1 **DELETE** Section 01 11 00 1.01 B. Summary of Work in its entirety and **REPLACE** with Section 01 11 00 1.01 B. Summary of Work listed below:
"Work shall be started within ten (10) calendar days after signing of Contract on behalf of Oregon State University. The Contract may not be signed prior to approval of the Contractor's Certificate of Insurance by Construction Contracts Administration (CCA), Oregon State University. Work shall be completed within ninety (90) calendar days of date of executed Contract"
- Item 2 **DELETE** Section 09 66 55 2.1 F. Rubber Sheet Flooring in its entirety and **REPLACE** with Section 09 66 55 2.1 F. Rubber Sheet Flooring listed below:
"Thickness: 18 mm. 3 mm EPDM wear layer and 15 mm PLAETech underlayment"

END OF ADDENDUM NO. 2