



Oregon State University

Burt Hall CRAC System Replacement CM/GC
PROJECT NUMBER: 2282-21

RFP #2025-017637

ADDENDUM NO. 1

ISSUE DATE: February 5, 2025

CONTRACT ADMINISTRATOR:

Thomas James

Construction Contracts Administration

Email: ConstructionContracts@oregonstate.edu

This Addendum is hereby issued to inform you of the following revisions and or clarifications to the above-referenced RFP and/or the Contract Documents for the Project, to the extent they have been modified herein. Any conflict or inconsistency between this Addendum and the Solicitation Document or any previous addenda will be resolved in favor of this Addendum. Proposals shall conform to this Addendum. Unless specifically changed by this Addendum, all other requirements, terms and conditions of the Solicitation Document and or Contract Documents, and any previous addenda, remain unchanged and can be modified only in writing by OSU. The following changes are hereby made:

QUESTIONS AND ANSWERS:

Item 1

1. Are the existing 4 CRAC units still functioning in any cooling capacity? Or are they completely offline at this time?
CCU 1 & CCU 2 are currently not functional and have no cooling capacity.
2. Are ASU-1 and CT-1 currently functional or completely offline?
CT-1 is not functional and is offline
ASU-1 is functional.

END OF ADDENDUM NO. 1