



**Oregon State**  
**University**

**COMPREHENSIVE RESERVE REQUEST FOR PROPOSAL (RFP)**  
**#2026-021254**  
**JEFFERSON AVENUE NORTH PARKING LOT IMPROVEMENTS**  
**CONSTRUCTION SERVICES**

**ADDENDUM NO. 1**

ISSUE DATE: April 16, 2026

**CONTRACT ADMINISTRATOR:**

Matt Hausman, Construction Contracts Officer

**Construction Contracts Administration**

**Email: [ConstructionContracts@oregonstate.edu](mailto:ConstructionContracts@oregonstate.edu)**

This Addendum is hereby issued to inform you of the following revisions and or clarifications to the above-referenced Solicitation and/or the Contract Documents for the Project, to the extent they have been modified herein. Any conflict or inconsistency between this Addendum and the Solicitation Document or any previous addenda will be resolved in favor of this Addendum. Proposals shall conform to this Addendum. Unless specifically changed by this Addendum, all other requirements, terms and conditions of the Solicitation Document and or Contract Documents, and any previous addenda, remain unchanged and can be modified only in writing by OSU. The following changes are hereby made:

**QUESTION/ANSWER**

Item 1 Q: Looking through the specifications it notes RMC or PVC covered RMC for underground conduit installations, and only references PVC conduit without noting that it is approved for underground conduit installation. Requesting that PVC conduit to be approved for the underground conduit for this project.

A: PVC conduit will be acceptable in underground applications for this project.

**END OF ADDENDUM NO. 1**