



# Oregon State University

## **COMPREHENSIVE RESERVE REQUEST FOR PROPOSAL (RFP)** **#2026-021254** **JEFFERSON AVENUE NORTH PARKING LOT IMPROVEMENTS** **CONSTRUCTION SERVICES**

### **ADDENDUM NO. 2**

ISSUE DATE: April 17, 2026

#### **CONTRACT ADMINISTRATOR:**

Matt Hausman, Construction Contracts Officer

**Construction Contracts Administration**

**Email:** [ConstructionContracts@oregonstate.edu](mailto:ConstructionContracts@oregonstate.edu)

This Addendum is hereby issued to inform you of the following revisions and or clarifications to the above-referenced Solicitation and/or the Contract Documents for the Project, to the extent they have been modified herein. Any conflict or inconsistency between this Addendum and the Solicitation Document or any previous addenda will be resolved in favor of this Addendum. Proposals shall conform to this Addendum. Unless specifically changed by this Addendum, all other requirements, terms and conditions of the Solicitation Document and or Contract Documents, and any previous addenda, remain unchanged and can be modified only in writing by OSU. The following changes are hereby made:

#### **QUESTION/ANSWER**

Item 1 Q: Item 3 of the bid form makes me believe a bid security is required. Can you please confirm that a bid security / bid bond is required for the Jefferson Ave North Parking Lot Improvements project? If required I need to know at what percent of bid total. In addition, if required, does OSU have a bid bond form or does our agent use the surety's form?

A: No Bid Security is required.

Item 2 Q: Can asphalt grindings be used for agg base in the reconstruction sections?

A: Asphalt millings may be incorporated into the aggregate base within the reconstruction areas, under supervision on site from the Owner representative. Millings are required to meet relevant Oregon Standard Specifications for gradation and compaction.

END OF ADDENDUM NO. 2