



Procurement, Contract & Risk Management

Klamath Falls:
541.885.1133 (office)
541.885.1115 (fax)
3201 Campus Drive
Snell Hall 112
Klamath Falls, OR 97601

Wilsonville:
503.821.1277 (office)
503.218.1126 (fax)
27500 SW Parkway Ave
Wilsonville, OR 97070

INVITATION TO BID #2015-01
TUNNEL LID REPLACEMENT PROJECT
RESPONSE TO CLARIFYING QUESTIONS
April 24, 2015

Note that these are questions submitted by interested firms to this solicitation. The below answers are for clarification purposes only and in no way alter or amend the BID as published.

The Proposed Contract Documents for this work are clarified as follows:

Drawings:

1. Sheet C2.C, Detail 1- Clarification: The top step of the stairway shall be cut into the top landing, similar to Details 3/C3.B
2. Sheet C3 and Detail 1/C6 – Clarification: The tunnel lid demolition and replacement shall extend easterly as shown on the drawings and end in line with the bottom of the adjacent stairway. The tunnel lid replacement does not extend into the upslope beside the stairway.

Specification:

1. Section 15770 – Clarification: The geothermal tubing shall penetrate and terminate inside the existing tunnels where directed by the Oregon Tech representative.

End of Questions